

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27848**  
**Work Order: 60802349\_01**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:14 |
| Sample Point:           | GHA-1HALL-BFB                | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27849**  
**Work Order: 60802349\_02**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:14 |
| Sample Point:           | GHA-1HALL-BFB-F              | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27850**  
**Work Order: 60802349\_03**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:15 |
| Sample Point:           | GHA-1HALL-BF                 | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27851**  
**Work Order: 60802349\_04**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:15 |
| Sample Point:           | GHA-1HALL-BF-F               | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27852**  
**Work Order: 60802349\_05**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:16 |
| Sample Point:           | GHA-1HALL-2-BFB              | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27853**  
**Work Order: 60802349\_06**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:16 |
| Sample Point:           | GHA-1HALL-2-BFB-F            | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27854**  
**Work Order: 60802349\_07**

System Name/Owner: 1751 GREATER HEIGHTS ACADEMY  
Collection Address: 3196 W PASADENA AVE, FLINT  
Collected By: MOLLY DEKRUGER  
Township/Well#/Section: //  
County: Genesee  
Sample Point: GHA-HALL-2-BFB  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 08/10/2026 08:20  
Date Received: 08/19/2026 08:52  
Purpose: Other

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27855**  
**Work Order: 60802349\_08**

System Name/Owner: 1751 GREATER HEIGHTS ACADEMY  
Collection Address: 3196 W PASADENA AVE, FLINT  
Collected By: MOLLY DEKRUGER  
Township/Well#/Section: //  
County: Genesee  
Sample Point: GHA-HALL-2-BFB-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 08/10/2026 08:20  
Date Received: 08/19/2026 08:52  
Purpose: Other

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27856**  
**Work Order: 60802349\_09**

System Name/Owner: 1751 GREATER HEIGHTS ACADEMY  
Collection Address: 3196 W PASADENA AVE, FLINT  
Collected By: MOLLY DEKRUGER  
Township/Well#/Section: //  
County: Genesee  
Sample Point: GHA-HALL-2-BF  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 08/10/2026 08:21  
Date Received: 08/19/2026 08:52  
Purpose: Other

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27857**  
**Work Order: 60802349\_10**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:21 |
| Sample Point:           | GHA-HALL-2-BF-F              | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27858**  
**Work Order: 60802349\_11**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:22 |
| Sample Point:           | GHA-HALL-3-BFB               | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27859**  
**Work Order: 60802349\_12**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:22 |
| Sample Point:           | GHA-HALL-3-BFB-F             | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27860**  
**Work Order: 60802349\_13**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:23 |
| Sample Point:           | GHA-HALL-BFB                 | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27861**  
**Work Order: 60802349\_14**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:23 |
| Sample Point:           | GHA-HALL-BFB-F               | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27862**  
**Work Order: 60802349\_15**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:24 |
| Sample Point:           | GHA-HALL-BF                  | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.**  
**630 South Saginaw**  
**Flint, MI 48502-1540**  
**810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU PO BOX 3081  
LANSING MI 48909

**Sample ID: LM27863**  
**Work Order: 60802349\_16**

|                         |                              |                 |                  |
|-------------------------|------------------------------|-----------------|------------------|
| System Name/Owner:      | 1751 GREATER HEIGHTS ACADEMY | WSSN/Pool ID:   |                  |
| Collection Address:     | 3196 W PASADENA AVE, FLINT   | Source:         | Other            |
| Collected By:           | MOLLY DEKRUGER               | Site Code:      | WIIN             |
| Township/Well#/Section: | //                           | Collector:      | Other            |
| County:                 | Genesee                      | Date Collected: | 08/10/2026 08:24 |
| Sample Point:           | GHA-HALL-BF-F                | Date Received:  | 08/19/2026 08:52 |
| Water System:           | Other                        | Purpose:        | Other            |

| TESTING INFORMATION |              |       |       |             | REGULATORY INFORMATION |           |           |
|---------------------|--------------|-------|-------|-------------|------------------------|-----------|-----------|
| Analyte Name        | Result       | Units | RL    | Date Tested | MCL/AL                 | Method    | CAS #     |
| Lead                | Not detected | mg/L  | 0.001 | 08/21/2026  | 0.012                  | EPA 200.8 | 7439-92-1 |

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Genesee County Health Dept.  
630 South Saginaw  
Flint, MI 48502-1540  
810 257-3603**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane